

Copy of the certificate regarding Water, Health and Sanitation issued by
Office Of the District Medical and Health Office, Dist. RangaReddy,Telangana



APPENDIX-XIII

**SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

Re.No.1506/D&O/DM&HO/RR/2026


Dated:11.05.2026

It is certified that an inspection team headed by Mr.M.Srinivasa Rao, Health Inspector, from DM&HO Office (Health Department), R.R Dist.

Inspected the **M/s. Brigade School, Located at Road No: 04, Near Beerappa Temple, Srinivasapuram Colony, Gurranguda, Balapur (Mandal), Ranga Reddy District.**


On 11.05.2026 and found that the **Brigade School** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year from the date of issue.

Signature with Seal: 
Name : Dr.D. Swarana Kumari, MBBS.
Designation: DM&HO, R.R.Dist.
Name & Address of the Office: District Medical & Health Officer
Ranga Reddy District.
Department:
District Medical & Health Office,
Shivarampally, Ranga Reddy District.

To,
The Principal
Brigade School,
Located at Road No: 04, Near Beerappa Temple, Srinivasapuram Colony,
Gurranguda, Balapur (Mandal), Ranga Reddy District.


PRINCIPAL
BRIGADE SCHOOL
Road No. 4, Srinivasa Puram Colony,
Gurranguda Village, Balapur Mandal,
Ranga Reddy Dist-501510.


MANAGER
BRIGADE SCHOOL
Road No. 4, Srinivasa Puram Colony,
Gurranguda Village, Balapur Mandal,
Ranga Reddy Dist-501510.

Copy of the Water Examination Report

GOVERNMENT OF TELANGANA
DEPARTMENT OF WATER AND WASTE WATER EXAMINATION
Directorate of I.P.M,P.H.Labs, Food (II) Administration, Narayanaguda.


REPORT OF BACTERIOLOGICAL ANALYSIS OF WATER

1. Sample From: Brigade School, Gurranguda, Hyderabad .
2. Collected by: Party
3. Collected on : 28-03-2026
4. Received on: 28-03-2026

Lab. Ref. No.	Source	Exact location	Residual Chlorine mg per liter	Total coliform bacteria (MPN Index) per 100ml	Faecal coliform bacteria per 100ml	Esch. coli per 100ml	Result
6214	Borewell water	School over head tank	Nil	Satisfactory
6216	Metro water	Municipal water line	...	15	Absent	Absent	Unsatisfactory for drinking purpose. Adequate chlorination is suggested
6218	R.O water	Water Purifier in main Hall	Nil	Satisfactory
6219	R.O water (TPC)	Water Purifier in main Hall	Total Aerobic Bacterial Plate Count for 24 hrs at 37 ^o c = 4 CFU / ml				Satisfactory


Dy. Chief Water Analyst


PRINCIPAL
BRIGADE SCHOOL
Road No. 4, Srinivasa Puram Colony,
Gurranguda Village, Balapur Mandal,
Ranga Reddy Dist-501510.


MANAGER
BRIGADE SCHOOL
Road No. 4, Srinivasa Puram Colony,
Gurranguda Village, Balapur Mandal,
Ranga Reddy Dist-501510.